



**MASINDE MULIRO UNIVERSITY OF SCIENCE AND TECHNOLOGY**  
*University of Choice*

**ADDENDUM NO. 2 OF 16<sup>TH</sup> MARCH, 2023**

Masinde Muliro University of Science and Technology wishes to notify bidders participating in the tender listed below of the **highlighted** changes

**Post Site visit for Tender for Proposed Solar Installation works Tender No. MMUST/015/SOALR/2022-2023 addendum items**

1. Page 72 of technical specifications. **Item 1.1.1- Change Poly/Mono to Mono.**
2. Page 162 in Bill of Quantities. **Expunge item No 21** in its entirety.
3. Page 162 in BOQ. Under B) LIBRARY SOLAR INSTALLATION- missing item, serial 2 should read

No	Description	Quantity	Rate	Amount (Kshs)
2	Carport solar ground mounting structure (aluminum rails and galvanised steel poles), complete with mid clamps, end clamps, and all other accessories (structure to securely hold the solar panels).	kW 30		

4. In single line diagram for library, under solar PV array- this should read “4 strings x 12 modules in series per inverter” rather than “4 strings x 14 modules in series per inverter”

